

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0554:147

Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Johnson Controls, 507 E Michigan St, Milwaukee, WI 53202-5211
Contact: Doug Kinney (414) 524-4358 Fax (414) 276-5979

DESIGN: Model 1951J ionization smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an ionization smoke detector for use with Notifier Models BX501, B610LP, B612LP, B614LP, B616LP, or B710LP bases (CSFM Listing No. 7300-0028:173) and separately listed compatible fire alarm control units. Model 1951J is suitable for open area protection at air velocities up to 1200 fpm. Refer to listee's Installation Instruction Manual for details

XLf: 7271-0028:201

06-21-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager